



MAURA T. HEALEY
Governor

KIMBERLEY DRISCOLL
Lieutenant Governor

The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Climate and Environmental Health
Community Sanitation Program
67 Forest Street, Suite # 100
Marlborough, MA 01752
Phone: 508-454-0870

KATHLEEN E. WALSH
Secretary

ROBERT GOLDSTEIN, MD, PhD
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

March 8, 2024

Joann Lynds, Superintendent
MCI Shirley
P.O. Box 1218
Shirley, MA 01464 (electronic copy)

Re: Plan of Correction – MCI Shirley

Dear Superintendent Lynds:

The Massachusetts Department of Public Health, Community Sanitation Program (CSP) has received your Plan of Correction in response to the inspection conducted on December 19, 20, and 21, 2023. After review, the CSP finds the plan appropriately addresses all of the violations noted in the report with the following exception:

1. Please confirm that hot water temperatures have been adjusted to meet regulatory requirements within the range of 100°F-112°F for showers and 110°F-130°F for handwash sinks.

Thank you for your prompt attention to this matter, should you have any questions please contact me at the address above.

Sincerely,

Hannah LeBeau
Environmental Health Inspector, CSP, BCEH

cc: Robert Goldstein, MD, PhD, Commissioner, DPH
Nalina Narain, Director, BCEH
Steven Hughes, Director, CSP, BCEH
Kathleen E. Walsh, Secretary, Executive Office of Health and Human Services (electronic copy)
Carol A. Mici, Commissioner, DOC (electronic copy)
Terrence Reidy, Secretary, EOPSS (electronic copy)
Brianna Arruda, Director, Policy Development and Compliance Unit (electronic copy)
Jessica Caffin, EHSO (electronic copy)
James Garreffo, RS, CHO, Director, Nashoba Associated Boards of Health (electronic copy)
Clerk, Massachusetts House of Representatives (electronic copy)
Clerk, Massachusetts Senate (electronic copy)