

The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Climate and Environmental Health
Division of Environmental Health Regulations and Standards
67 Forest Street, Suite # 100
Marlborough, MA 01752
Phone: 617-624-6000

MAURA T. HEALEY
Governor

KIMBERLEY DRISCOLL
Lieutenant Governor

KATHLEEN E. WALSH
Secretary

ROBERT GOLDSTEIN, MD, PhD
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

March 14, 2025

To: Shawn Jenkins, Commissioner, Department of Corrections (electronic copy)
Kathleen E. Walsh, Secretary, Executive Office of Health and Human Services (electronic copy)
Clerk, Massachusetts House of Representatives (electronic copy)
Clerk, Massachusetts Senate (electronic copy)
Tyler Crocker, Environmental Health and Safety Officer (electronic copy)

Greetings,

Pursuant to 105 CMR 451.403, please find the inspection report for Suffolk County Jail, the Plan of Correction (POC) from the facility and the POC acceptance letter from the Division of Environmental Health Regulations and Standards (EHRS).

Sincerely,

Hannah LeBeau
Environmental Health Inspector, EHRS, BCEH

Cc: Robert Goldstein, MD, PhD, Commissioner, DPH (electronic copy)
Terrence Reidy, Secretary, Executive Office of Public Safety and Security (electronic copy)
Daniel J. Prendergast, Assistant Commissioner ISD/ Health Division, City of Boston (electronic copy)
Brianna Arruda, Director, Policy Development and Compliance Unit (electronic copy)
Jose Mojica, Superintendent (electronic copy)



MAURA T. HEALEY
Governor

KIMBERLEY DRISCOLL
Lieutenant Governor

The Commonwealth of Massachusetts

Executive Office of Health and Human Services

Department of Public Health

Bureau of Climate and Environmental Health

Division of Environmental Health Regulations and Standards

67 Forest Street, Suite # 100

Marlborough, MA 01752

Phone: 617-624-5757

KATHLEEN E. WALSH
Secretary

ROBERT GOLDSTEIN, MD, PhD
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

January 15, 2025

Steven W. Tompkins, Sheriff
Suffolk County Sheriff's Department
20 Bradston Street
Boston, MA 02118 (electronic copy)

Re: Facility Inspection – Suffolk County Jail, Boston

Dear Sheriff Tompkins:

The Massachusetts Department of Public Health (Department) Division of Environmental Health Regulations and Standards (EHRS) conducted an inspection of the Suffolk County House of Corrections on November 8, 2024, accompanied by Sergeant Tyler Crocker, Environmental Health and Safety Officer, in accordance with Department regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities.

The inspection identified 132 total deficiencies: 77 deficiencies under the Required Standards (.100 and .200 series), 18 repeat deficiencies under the Required Standards, 20 deficiencies under the Recommended Standards (.300 series), and 17 repeat deficiencies under the Recommended Standards.

Overview

Section 1 provides details of all deficiencies, including repeat deficiencies, found during the inspection. These are categorized by Required Standards, Recommended Standards, or additional applicable regulatory standards.

Section 2 provides information on areas that EHRS found to be compliant.

Section 3 documents the areas that EHRS did not inspect.

Section 4 provides information on submitting a Plan of Correction for the identified deficiencies.

Section 5 outlines observations and recommendations related to the inspection.

SECTION 1: Health and Safety Deficiencies

Deficiencies under the Required Standards (.100 and .200 series)

77 new deficiencies and 18 repeat deficiencies (indicated by an *) were found during the inspection:

1.	Floor 6.5	Gym		105 CMR 451.200	Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, single-use cups stored on floor
2.	6th Floor	Staff Bathroom 6-1 & 6-2		105 CMR 451.110(A)	Hygiene Supplies at Toilet and Handwash Sink: No soap at handwash sink
3.	6th Floor	Staff Bathroom 6-1 & 6-2		105 CMR 451.117	Toilet Fixtures: Toilet fixture dirty
4.	6th Floor	Unit 6-1A	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 2, 6, and 8
5.	6th Floor	Unit 6-1	Kitchenette	105 CMR 451.200	Food Storage, Preparation and Service: Food preparation not in compliance with 105 CMR 590.000, interior of microwave oven dirty
6.	6th Floor	Unit 6-1	Kitchenette	105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, hot water control leaking at handwash sink
7.	6th Floor	Unit 6-1	Shower # 618 – Bottom Tier, Right Side	105 CMR 451.123	Maintenance: Light shield rusted
8.	6th Floor	Unit 6-1	Shower # 618 – Bottom Tier, Right Side	105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, drain cover damaged
9.	6th Floor	Unit 6-1	Shower # 618 – Bottom Tier, Right Side	105 CMR 451.123*	Maintenance: Ceiling dirty
10.	6th Floor	Unit 6-1	Shower # 711 - Top Tier, Left Side	105 CMR 451.123*	Maintenance: Ceiling paint damaged
11.	6th Floor	Unit 6-1	Shower # 711 - Top Tier, Left Side	105 CMR 451.123*	Maintenance: Wall paint damaged
12.	6th Floor	Unit 6-1	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 13, 15, 18, 19, 27, 29, 32, and 35
13.	6th Floor	Unit 6-3 (Safekeep for BPD)	Shower # 63E	105 CMR 451.123	Maintenance: Drain flies observed
14.	6th Floor	Unit 6-3 (Safekeep for BPD)	Shower # 63E	105 CMR 451.123	Maintenance: Shower curtain missing
15.	6th Floor	Unit 6-3 (Safekeep for BPD)	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 21
16.	6th Floor	Unit 6-3 (Safekeep for BPD)	Kitchenette	105 CMR 451.126*	Hot Water for Bathing and Hygiene: No hot water supplied to handwash sink

17. 6th Floor	Unit 6-4	Shower # 64D	105 CMR 451.123	Maintenance: Walls dirty
18. 6th Floor	Unit 6-4	Shower # 64G	105 CMR 451.123	Maintenance: Walls dirty
19. 6th Floor	Unit 6-4	Shower # 64G	105 CMR 451.123	Maintenance: Wall paint damaged
20. 6th Floor	Unit 6-4	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell 14
21. 5th Floor	Medical Area	Nurse's Area	105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, handwash sink out-of-order
22. 5th Floor	Medical Area	Bathroom # 5032	105 CMR 451.126*	Hot Water for Bathing and Hygiene: No hot water supplied to handwash sink; hot water push button broken
23. 5th Floor	Medical Housing Unit	Shower # 55C	105 CMR 451.123	Maintenance: Ceiling dirty
24. 5th Floor	Medical Housing Unit	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 5559
25. 5th Floor	Psychiatric Housing Unit # 5552	Cells # 5564-5570	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 5567
26. 5th Floor	Psychiatric Housing Unit # 5552	Shower # 55B	105 CMR 451.123	Maintenance: Ceiling dirty
27. 5th Floor	Psychiatric Housing Unit # 5552	Shower # 55B	105 CMR 451.123	Maintenance: Door frame rusted
28. 4th Floor	Unit 4-1	Shower # 41I	105 CMR 451.123	Maintenance: Shower curtain missing
29. 4th Floor	Unit 4-1	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 1, 5, 6, 7, 12, and 17
30. 4th Floor	Unit 4-2	Shower # 42E (near cell # 15)	105 CMR 451.123	Maintenance: Shower curtain missing
31. 4th Floor	Unit 4-2	Shower # 42 H (near cell # 34)	105 CMR 451.123	Maintenance: Shower curtain missing
32. 4th Floor	Unit 4-2	Shower # 42I (near cell # 32)	105 CMR 451.123	Maintenance: Shower curtain missing
33. 4th Floor	Unit 4-2	Shower # 42I (near cell # 32)	105 CMR 451.123	Maintenance: Debris in drain cover
34. 4th Floor	Unit 4-2	Shower # 42I (near cell # 32)	105 CMR 451.123	Maintenance: Wall damaged near push button
35. 4th Floor	Unit 4-2	Cells (Unoccupied)	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 8, 12, and 25
36. 4th Floor	Unit 4-3	Shower # 43H	105 CMR 451.123	Maintenance: Shower curtain missing
37. 4th Floor	Unit 4-3	Kitchenette	105 CMR 451.110(A) *	Hygiene Supplies at Toilet and Handwash Sink: Electric hand dryer out-of-order
38. 4th Floor	Unit 4-3	Shower # 43I (near cell # 20)	105 CMR 451.123*	Maintenance: Walls dirty
39. 4th Floor	Unit 4-3	Shower # 43E	105 CMR 451.123*	Maintenance: Walls dirty
40. 4th Floor	Unit 4-3	Shower # 43C	105 CMR 451.123*	Maintenance: Walls dirty
41. 4th Floor	Control 4-3 & 4-4	Staff Bathroom	105 CMR 451.126*	Hot Water for Bathing and Hygiene: Hot water temperature 72°F at handwash sink

42. 4th Floor	Unit 4-4	Kitchenette	105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, handwash sink leaking
43. 4th Floor	Unit 4-4	Kitchenette	105 CMR 451.110(A) *	Hygiene Supplies at Toilet and Handwash Sink: Electric hand dryer out-of-order
44. 4th Floor	Unit 4-4	Shower # 44I (near cell # 28)	105 CMR 451.123*	Maintenance: Ceiling dirty
45. 4th Floor	Unit 4-4	Shower # 44I (near cell # 28)	105 CMR 451.123*	Maintenance: Walls dirty
46. 4th Floor	Unit 4-4	Shower # 44H (near cell # 9)	105 CMR 451.123*	Maintenance: Walls dirty
47. 4th Floor	Unit 4-4	Shower # 44J (near Visiting Rooms)	105 CMR 451.123	Maintenance: Shower curtain missing
48. 4th Floor	Unit 4-4	Shower # 44B	105 CMR 451.123	Maintenance: Shower curtain missing
49. 4th Floor	Unit 4-4	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 9, 33, and 34
50. Floor 3.5	Education	Bathroom # 3521	105 CMR 451.110(A)	Hygiene Supplies at Toilet and Handwash Sink: No paper towels at handwash sink
51. 2nd Floor	Unit 2-2	Shower # 22C (near slop sink room # 22D)	105 CMR 451.123	Maintenance: Dead drain flies observed on ceiling
52. 2nd Floor	Unit 2-2	Shower # 22C (near slop sink room # 22D)	105 CMR 451.123	Maintenance: Shower curtain missing
53. 2nd Floor	Unit 2-2	Shower # 22C (near slop sink room # 22D)	105 CMR 451.123	Maintenance: Walls dirty
54. 2nd Floor	Unit 2-2	Shower # 22E (near cell # 15)	105 CMR 451.123	Maintenance: Objectionable odor observed
55. 2nd Floor	Unit 2-2	Shower # 22E (near cell # 15)	105 CMR 451.123*	Maintenance: Shower curtain missing
56. 2nd Floor	Unit 2-2	Shower # 22H (near cell # 34)	105 CMR 451.123	Maintenance: Wall paint damaged
57. 2nd Floor	Unit 2-2	Shower # 22I (near cell # 32)	105 CMR 451.123	Maintenance: Walls dirty
58. 2nd Floor	Unit 2-2	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 1, 5, 13, 15, and 17
59. Contact Visits/Roll Call	Classification		105 CMR 451.200	Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, refrigerator gaskets moldy and damaged
60. Entry Level	Communications Office # 1080		105 CMR 451.200	Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, excessive ice build-up observed in freezer
61. Entry Level	Blue Shirt's Locker Room # 1075		105 CMR 451.110(A) *	Hygiene Supplies at Toilet and Handwash Sink: Electric hand dryer out-of-order

62. Entry Level	Blue Shirt's Locker Room # 1075	105 CMR 451.123*	Maintenance: Ceiling tiles water damaged	
63. Ground Level	Staff Bathroom # G5	105 CMR 451.123	Maintenance: Ceiling vent dusty	
64. Ground Level	Staff Bathroom # G5	105 CMR 451.123	Maintenance: Wall paint damaged	
65. Ground Level	Staff Bathroom # G5	105 CMR 451.123	Maintenance: Ceiling water damaged	
66. Ground Level	Back Gate Control # G80	105 CMR 451.200	Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, excessive ice build-up in freezer	
67. Ground Level	West Mechanical # G18	105 CMR 451.130*	Plumbing: Plumbing not maintained in good repair, hot water supply leaking	
68. Food Service	Oven and Steamer Hood Area	105 CMR 451.200	Maintenance and Operation; Premises, Structure, Attachments, and Fixtures - Methods: Facility not cleaned as often as necessary, rodent droppings observed behind ovens. Standard found in 105 CMR 590; FC 6-501.12(A).	
69. Food Service	Storage Cage	105 CMR 451.200	Maintenance and Operation; Premises, Structure, Attachments, and Fixtures - Methods: Facility not cleaned as often as necessary, rodent droppings observed. Standard found in 105 CMR 590; FC 6-501.12(A).	
70. Food Service	Vegetable Walk-in # 3	105 CMR 451.200	Limitation of Growth of Organisms of Public Health Concern, Temperature and Time Control: Refrigerated time/temperature control for safety food prepared on site not clearly marked indicating the date or day by which the food shall be consumed or discarded (Pf). Standard found in 105 CMR 590; FC 3-501.17(A)	Corrected on-site
71. Food Service	Vegetable Walk-in # 3	105 CMR 451.200	Characteristics; Condition: Food not safe, unadulterated, and honestly presented (Pf), moldy produce observed. Standard found in 105 CMR 590; FC 3-101.11.	Corrected on-site

72. Food Service	Milk Walk-in # 4	105 CMR 451.200	Preventing Contamination after Receiving; Preventing Food and Ingredient Contamination: Food not appropriately covered. Standard found in 105 CMR 590; FC 3-302.11(A)(4).	Corrected on-site
73. Food Service	Mop Cage	105 CMR 451.200	Maintenance and Operation; Premises, Structure, Attachments, and Fixtures - Methods: Facility not cleaned as often as necessary, rodent droppings observed. Standard found in 105 CMR 590; FC 6-501.12(A).	

Deficiencies under the Recommended Standards (.300 series)

20 new deficiencies and 17 repeat deficiencies (indicated by an *) were found during the inspection:

1. 6th Floor	Unit 6-1A	Storage Room # 61G	105 CMR 451.360	Protective Measures: Rodent droppings observed
2. 6th Floor	Unit 6-1A	Kitchenette	105 CMR 451.360*	Protective Measures: Rodent droppings observed
3. 6th Floor	Unit 6-1A	Slop Sink Room # 61B	105 CMR 451.360*	Protective Measures: Rodent droppings observed
4. 6th Floor	Unit 6-1	Slop Sink Room	105 CMR 451.353	Interior Maintenance: Wet mop stored upside down
5. 6th Floor	Unit 6-1	Second Floor Storage Room	105 CMR 451.360*	Protective Measures: Rodent droppings observed
6. 6th Floor	Unit 6-3 (Safekeep for BPD)	Kitchenette	105 CMR 451.353*	Interior Maintenance: Handwash sink dirty
7. 6th Floor	Unit 6-3 (Safekeep for BPD)	Kitchenette	105 CMR 451.360*	Protective Measures: Rodent droppings observed
8. 6th Floor	Unit 6-4	Cells	105 CMR 451.353	Interior Maintenance: Ceiling dirty in cell # 17
9. 6th Floor	Unit 6-4	Cells	105 CMR 451.353	Interior Maintenance: Wall vent blocked in cell # 8, 11, and 27
10. 5th Floor	Psychiatric Housing Unit # 5552	Storage # 5555	105 CMR 451.383(B)	Fire Safety System: Facility not in compliance with 780 CMR Massachusetts Building Code provisions for fire safety
11. 5th Floor	Medical Area	Male Staff Bathroom # 5093	105 CMR 451.353*	Interior Maintenance: Floor damaged outside bathroom
12. 4th Floor	Unit 4-1	Kitchenette	105 CMR 451.360	Protective Measures: Rodent droppings observed
13. 4th Floor	Unit 4-1	Kitchenette	105 CMR 451.353	Interior Maintenance: Handwash sink dirty
14. 4th Floor	Unit 4-1	Slop Sink Room # 41N	105 CMR 451.353	Interior Maintenance: Wet mop stored in bucket

15. 4th Floor	Unit 4-1	Storage Closet	105 CMR 451.360	Protective Measures: Rodent droppings observed
16. 4th Floor	Unit 4-1	Storage Closet	105 CMR 451.353	Interior Maintenance: Wet mop stored in bucket
17. 4th Floor	Unit 4-2	Kitchenette	105 CMR 451.360	Protective Measures: Rodent droppings observed
18. 4th Floor	Unit 4-4	Common Area	105 CMR 451.353	Interior Maintenance: Mold observed on ceiling near closet # 44G
19. 4th Floor	Unit 4-4	Common Area	105 CMR 451.353	Interior Maintenance: Wall mounted telephone # 1 out-of-order
20. 4th Floor	Unit 4-4	Common Area	105 CMR 451.353*	Interior Maintenance: Ceiling damaged near closet # 44G
21. 4th Floor	Unit 4-4	Kitchenette	105 CMR 451.360*	Protective Measures: Rodent droppings observed
22. 4th Floor	Unit 4-4	Closet # 44G	105 CMR 451.360*	Protective Measures: Rodent droppings observed
23. 4th Floor	Unit 4-4	Slop Sink Room # 44C	105 CMR 451.353	Interior Maintenance: Wet mop stored upside down
24. 4th Floor	Unit 4-4	Slop Sink Room # 44C	105 CMR 451.353	Interior Maintenance: Chemical bottle leaking
25. 4th Floor	Unit 4-4	Cells	105 CMR 451.353	Interior Maintenance: Wall vent blocked in cell # 8
26. 2nd Floor	Control 2-1 & 2-2	Main Area	105 CMR 451.353	Desk surface damaged
27. Entry Level	Weight Room # 1070		105 CMR 451.353*	Interior Maintenance: Floor tiles damaged
28. Ground Level	Store Room # G11		105 CMR 451.353	Interior Maintenance: Wet mop stored in bucket
29. Ground Level	Loading Dock # G26		105 CMR 451.350*	Structural Maintenance: Garage door not rodent and weathertight
30. Ground Level	Laundry Room # G23/G29		105 CMR 451. 353*	Interior Maintenance: Ceiling water damaged in storage closet
31. Ground Level	Loading Dock # G26		105 CMR 451.360*	Protective Measures: Rodent droppings observed
32. Ground Level	Garbage Room # G37		105 CMR 451.350*	Structural Maintenance: Garage door not rodent and weathertight
33. Ground Level	Garbage Room # G37		105 CMR 451.360*	Protective Measures: Rodent droppings observed on floor
34. Ground Level	Boston Police Booking Area		105 CMR 451.353*	Interior Maintenance: Ceiling tiles missing, and water damaged
35. Ground Level	Male Booking Area	Control	105 CMR 451.353*	Interior Maintenance: Floor damaged

SECTION 2: Areas Found to be in Compliance

EHRS inspected 102 additional areas of the facility which were found to be in compliance.

Section 3: Areas EHRS did not inspect

EHRS did not inspect 13 areas of the facility because they were either in use, locked, or under construction.

1. Floor 6.5	Storage Room # 6504	Unable to Inspect - Locked
--------------	---------------------	----------------------------

2.	Floor 6.5	Inmate Bathroom # 6505	Unable to Inspect - Not in Use
3.	Floor 6.5	Inmate Bathroom # 6506	Unable to Inspect - Not in Use
4.	6th Floor	Unit 6-4 Storage Room # 64F	Unable to Inspect - Locked
5.	5th Floor	Medical Area Room # 5029	Unable to Inspect - In Use
6.	5th Floor	Psychiatric Housing Shower # 55A Unit # 5552	Unable to Inspect - In Use
7.	4th Floor	Unit 4-1 Shower # 41G (near cell # 10)	Unable to Inspect - In Use
8.	4th Floor	Unit 4-2 Storage Room # 42F	Unable to Inspect - Locked
9.	4th Floor	Unit 4-2 Shower # 42G	Unable to Inspect - In Use
10.	Floor 3.5	Education Bathroom # 3520	Unable to Inspect - In Use
11.	2nd Floor	Unit 2-1	Unable to Inspect - Under Construction
12.	2nd Floor	Unit 2-3	Unable to Inspect - Under Construction
13.	2nd Floor	Unit 2-4	Unable to Inspect - Under Construction

SECTION 5: Plan of Correction

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice. The Plan of Correction must include:

1. Specific corrective steps to be taken
2. A timetable for the corrective actions for larger projects
3. The date by which correction will be achieved
4. Any interim measures being implemented to ensure the health and safety of incarcerated individuals and facility staff
5. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

SECTION 4: Observations and Recommendations

1. The inmate population was 318 at the time of the inspection.
2. At the time of inspection, the EHRS recommended re-numbering all showers throughout the institution. This will assist the EHRS and Sheriff's Department employees to better recognize where issues exist.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" [105 CMR 451.000](#) is available in both PDF and RTF formats. For more specific information about the food standards, you can download the merged food code, which can be found [here](#).

An inspection may also include observations of other conditions which could constitute a threat to the health or safety of inmates or employees, including but not limited to the standards set forth by the Department as follows, and report on such pursuant to 451.402(B). You can use these links below to review these standards:


- [105 CMR 205.000](#): Minimum Standards Governing Medical Records and Conduct of Physical Examinations in Correctional Facilities
- [105 CMR 480.000](#): Minimum requirements for the Management of Medical or Biological Waste
- [105 CMR 500.000](#): Good Manufacturing Practices for Food

This inspection report is true and accurate to the best of my knowledge.

Sincerely,

A handwritten signature in blue ink that reads "Hannah LeBeau". The signature is written in a cursive, flowing style.

Hannah LeBeau
Environmental Health Inspector, EHRS, BCEH



STEVEN W. TOMPKINS
SHERIFF

Suffolk County Sheriff's Department

Jail
200 Nashua Street
Boston, MA 02114
(617) 635-1100

House of Correction
20 Bradston Street
Boston, MA 02118
(617) 635-1000



January 27, 2025

Hannah LeBeau, Environmental Health Inspector
Commonwealth of Massachusetts
Department of Public Health
5 Randolph Street
Canton, MA 02021


Dear Inspector LeBeau:

Enclosed is this Department's updated Plan of Action, produced by Lt. Brittney Carroll to correct deficiencies noted in your Minimum Health and Sanitation Standards Inspection of the Suffolk County Jail. Deficiencies were addressed with the dates they were completed. There was recently a shower projected completed by Pavilion flooring that addressed all of the noted concerns in 21, 22, 42 and 64 unit showers. We are also preparing for an upcoming plumbing project that will be a massive overhaul of the whole plumbing system within the facility. The projected start date for that is July 2025. We thank you for your commitment to helping us improve the conditions within our facility.

Sincerely,

Leteya Flambo
Assistant Superintendent
(617) 704-6703

Enc. Plan of Action



MAURA T. HEALEY
Governor

KIMBERLEY DRISCOLL
Lieutenant Governor

The Commonwealth of Massachusetts

Executive Office of Health and Human Services

Department of Public Health

Bureau of Climate and Environmental Health

Division of Environmental Health Regulations and Standards

67 Forest Street, Suite # 100

Marlborough, MA 01752

Phone: 617-624-5757

KATHLEEN E. WALSH
Secretary

ROBERT GOLDSTEIN, MD, PhD
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

January 15, 2025

Steven W. Tompkins, Sheriff
Suffolk County Sheriff's Department
20 Bradston Street
Boston, MA 02118 (electronic copy)

Re: Facility Inspection – Suffolk County Jail, Boston

Dear Sheriff Tompkins:

The Massachusetts Department of Public Health (Department) Division of Environmental Health Regulations and Standards (EHRS) conducted an inspection of the Suffolk County House of Corrections on November 8, 2024, accompanied by Sergeant Tyler Crocker, Environmental Health and Safety Officer, in accordance with Department regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities.

The inspection identified 132 total deficiencies: 77 deficiencies under the Required Standards (.100 and .200 series), 18 repeat deficiencies under the Required Standards, 20 deficiencies under the Recommended Standards (.300 series), and 17 repeat deficiencies under the Recommended Standards.

Overview

Section 1 provides details of all deficiencies, including repeat deficiencies, found during the inspection. These are categorized by Required Standards, Recommended Standards, or additional applicable regulatory standards.

Section 2 provides information on areas that EHRS found to be compliant.

Section 3 documents the areas that EHRS did not inspect.

Section 4 provides information on submitting a Plan of Correction for the identified deficiencies.

Section 5 outlines observations and recommendations related to the inspection.

SECTION 1: Health and Safety Deficiencies

Deficiencies under the Required Standards (.100 and .200 series)

77 new deficiencies and 18 repeat deficiencies (indicated by an *) were found during the inspection:

1.	Floor 6.5	Gym		105 CMR 451.200	Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, single-use cups stored on floor <i>All kitchen supplies was removed from the gym and placed on pallets in the 2-4 unit on 11/18/2024</i>
2.	6th Floor	Staff Bathroom 6-1 & 6-2		105 CMR 451.110(A)	Hygiene Supplies at Toilet and Handwash Sink: No soap at handwash sink <i>Hygiene supplies replenished on 11/8/2024</i>
3.	6th Floor	Staff Bathroom 6-1 & 6-2		105 CMR 451.117	Toilet Fixtures: Toilet fixture dirty <i>Cleaned on 11/08/2024</i>
4.	6th Floor	Unit 6-1A	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 2, 6, and 8 <i>All mattresses were replaced by Dep. Pena on 11/11/2024</i>
5.	6th Floor	Unit 6-1	Kitchenette	105 CMR 451.200	Food Storage, Preparation and Service: Food preparation not in compliance with 105 CMR 590.000, interior of microwave oven dirty <i>Microwave was sanitized by unit workers and inspected by the unit officer on 11/08/2024</i>
6.	6th Floor	Unit 6-1	Kitchenette	105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, hot water control leaking at handwash sink <i>Sink repair made by Sgt. Allard on 11/15/2024</i>
7.	6th Floor	Unit 6-1	Shower # 618 – Bottom Tier, Right Side	105 CMR 451.123	Maintenance: Light shield rusted <i>Scheduled for repair by the maintenance department by 2/28/2025</i>
8.	6th Floor	Unit 6-1	Shower # 618 – Bottom Tier, Right Side	105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, drain cover damaged <i>Scheduled for repair by the maintenance department by 2/28/2025.</i>
9.	6th Floor	Unit 6-1	Shower # 618 – Bottom Tier, Right Side	105 CMR 451.123*	Maintenance: Ceiling dirty <i>-Cleaned 11/08/2024</i>
10.	6th Floor	Unit 6-1	Shower # 711 - Top Tier, Left Side	105 CMR 451.123*	Maintenance: Ceiling paint damaged <i>Scheduled for repaint by the maintenance department by 2/28/2025</i>
11.	6th Floor	Unit 6-1	Shower # 711 -	105 CMR 451.123*	Maintenance: Wall paint damaged

		Top Tier, Left Side		<i>Scheduled for repaint by the maintenance department by 2/28/2025</i>
12. 6th Floor	Unit 6-1	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 13, 15, 18, 19, 27, 29, 32, and 35 <i>All mattresses were replaced by Dep. Pena on 11/11/2024</i>
13. 6th Floor	Unit 6-3 (Safekeep for BPD)	Shower # 63E	105 CMR 451.123	Maintenance: Drain flies observed <i>Shower cleaned on 11/08/2024 by overnight detainee detail</i>
14. 6th Floor	Unit 6-3 (Safekeep for BPD)	Shower # 63E	105 CMR 451.123	Maintenance: Shower curtain missing <i>Shower curtain replaced 11/09/2024</i>
15. 6th Floor	Unit 6-3 (Safekeep for BPD)	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 21 <i>All mattresses were replaced by Dep. Pena on 11/11/2024</i>
16. 6th Floor	Unit 6-3 (Safekeep for BPD)	Kitchenette	105 CMR 451.126*	Hot Water for Bathing and Hygiene: No hot water supplied to handwash sink <i>Water fixed and Temps adjusted to 110-130 degree F on 11/15/2024 by Dep. Lorse</i>
17. 6th Floor	Unit 6-4	Shower # 64D	105 CMR 451.123	Maintenance: Walls dirty <i>Shower cleaned on 11/08/2024 by overnight detainee detail</i> <i>-Sole Source/Pavilion Floors shower repair project completed 12/23/2024</i>
18. 6th Floor	Unit 6-4	Shower # 64G	105 CMR 451.123	Maintenance: Walls dirty <i>Shower cleaned on 11/08/2024 by overnight detainee detail</i> <i>-Sole Source/Pavilion Floors shower repair project completed 12/23/2024</i>
19. 6th Floor	Unit 6-4	Shower # 64G	105 CMR 451.123	Maintenance: Wall paint damaged <i>Sole Source/Pavilion Floors shower repair project completed 12/23/2024</i>
20. 6th Floor	Unit 6-4	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell 14 <i>All mattresses were replaced by Dep. Pena on 11/11/2024</i>
21. 5th Floor	Medical Area	Nurse's Area	105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, handwash sink out-of-order <i>Plumbing repair made by Sgt. Allard on 11/21/2024</i>
22. 5th Floor	Medical Area	Bathroom # 5032	105 CMR 451.126*	Hot Water for Bathing and Hygiene: No hot water supplied to handwash sink; hot water push button broken <i>-Temps adjusted to 110-130 degree F on 11/15/2024 by Dep. Lorse</i>

				<i>-Medical vendor / Christina Benner notified of push button replacement needed on 11/09/2024</i>
23. 5th Floor	Medical Housing Unit	Shower # 55C	105 CMR 451.123	Maintenance: Ceiling dirty <i>Shower clean on 11/8/2024</i>
24. 5th Floor	Medical Housing Unit	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 5559 <i>All mattresses were replaced by Dep. Pena on 11/11/2024</i>
25. 5th Floor	Psychiatric Housing Unit # 5552	Cells # 5564-5570	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 5567 <i>All mattresses were replaced by Dep. Pena on 11/11/2024</i>
26. 5th Floor	Psychiatric Housing Unit # 5552	Shower # 55B	105 CMR 451.123	Maintenance: Ceiling dirty <i>Shower cleaned on 11/08/2025</i>
27. 5th Floor	Psychiatric Housing Unit # 5552	Shower # 55B	105 CMR 451.123	Maintenance: Door frame rusted <i>Scheduled for repaint by the maintenance department by 2/28/2025</i>
28. 4th Floor	Unit 4-1	Shower # 41I	105 CMR 451.123	Maintenance: Shower curtain missing <i>Shower curtain replaced on 11/9/2024</i>
29. 4th Floor	Unit 4-1	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 1, 5, 6, 7, 12, and 17 <i>All mattresses were replaced by Dep. Pena on 11/11/2024</i>
30. 4th Floor	Unit 4-2	Shower # 42E (near cell # 15)	105 CMR 451.123	Maintenance: Shower curtain missing <i>Shower curtain replaced on 11/9/2024</i>
31. 4th Floor	Unit 4-2	Shower # 42 H (near cell # 34)	105 CMR 451.123	Maintenance: Shower curtain missing <i>Shower curtain replaced on 11/9/2024</i>
32. 4th Floor	Unit 4-2	Shower # 42I (near cell # 32)	105 CMR 451.123	Maintenance: Shower curtain missing <i>Shower curtain replaced on 11/9/2024</i>
33. 4th Floor	Unit 4-2	Shower # 42I (near cell # 32)	105 CMR 451.123	Maintenance: Debris in drain cover <i>Shower cleaned 11/08/2024</i>
34. 4th Floor	Unit 4-2	Shower # 42I (near cell # 32)	105 CMR 451.123	Maintenance: Wall damaged near push button <i>Sole Source/Pavilion Floors shower repair project completed for this unit on 1/17/2025.</i>
35. 4th Floor	Unit 4-2	Cells (Unoccupied)	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 8, 12, and 25 <i>All mattresses were replaced by Dep. Pena on 11/11/2024</i>
36. 4th Floor	Unit 4-3	Shower # 43H	105 CMR 451.123	Maintenance: Shower curtain

				missing <i>Shower curtain replaced on 11/09/2024</i>
37. 4th Floor	Unit 4-3	Kitchenette	105 CMR 451.110(A) *	Hygiene Supplies at Toilet and Handwash Sink: Electric hand dryer out-of-order <i>Department Electrician, Robert Jackson, notified. Excepted replacement before 1/31/2025</i>
38. 4th Floor	Unit 4-3	Shower # 43I (near cell # 20)	105 CMR 451.123*	Maintenance: Walls dirty <i>Cleaned 11/08/2024. Power wash by overnight detail on 11/14/2024</i>
39. 4th Floor	Unit 4-3	Shower # 43E	105 CMR 451.123*	Maintenance: Walls dirty <i>Cleaned 11/08/2024. Power wash by overnight detail on 11/14/2024</i>
40. 4th Floor	Unit 4-3	Shower # 43C	105 CMR 451.123*	Maintenance: Walls dirty <i>Cleaned 11/08/2024. Power wash by overnight detail on 11/14/2024</i>
41. 4th Floor	Control 4-3 & 4-4	Staff Bathroom	105 CMR 451.126*	Hot Water for Bathing and Hygiene: Hot water temperature 72°F at handwash sink <i>Hot water Temp adjusted by Ofc. Lorse on 11/15/2024 to 100-130 degrees F.</i>
42. 4th Floor	Unit 4-4	Kitchenette	105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, handwash sink leaking <i>Repaired made on 11/17/2024 by Sgt. Allard. Replaced rubber gasket.</i>
43. 4th Floor	Unit 4-4	Kitchenette	105 CMR 451.110(A) *	Hygiene Supplies at Toilet and Handwash Sink: Electric hand dryer out-of-order <i>Department Electrician, Robert Jackson, notified. Excepted replacement before 1/31/2025</i>
44. 4th Floor	Unit 4-4	Shower # 44I (near cell # 28)	105 CMR 451.123*	Maintenance: Ceiling dirty <i>Cleaned on 11/09/2024. Power wash by overnight detail on 11/14/2024</i>
45. 4th Floor	Unit 4-4	Shower # 44I (near cell # 28)	105 CMR 451.123*	Maintenance: Walls dirty <i>Cleaned on 11/09/2024. Power wash by overnight detail on 11/14/2024</i>
46. 4th Floor	Unit 4-4	Shower # 44H (near cell # 9)	105 CMR 451.123*	Maintenance: Walls dirty <i>Cleaned on 11/09/2024. Power wash by overnight detail on 11/14/2024</i>
47. 4th Floor	Unit 4-4	Shower # 44J (near Visiting Rooms)	105 CMR 451.123	Maintenance: Shower curtain missing <i>Shower curtain replaced on 11/09/2024</i>
48. 4th Floor	Unit 4-4	Shower # 44B	105 CMR 451.123	Maintenance: Shower curtain missing <i>Shower curtain replaced on 11/09/2024</i>

49. 4th Floor	Unit 4-4	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 9, 33, and 34 <i>All mattresses were replaced by Dep. Pena on 11/11/2024</i>
50. Floor 3.5	Education	Bathroom # 3521	105 CMR 451.110(A)	Hygiene Supplies at Toilet and Handwash Sink: No paper towels at handwash sink <i>Hygiene supply replaced on 11/11/2024 by Buildings and ground crew</i>
51. 2nd Floor	Unit 2-2	Shower # 22C (near slop sink room # 22D)	105 CMR 451.123	Maintenance: Dead drain flies observed on ceiling <i>Cleaned 11/9/2024. Sole Source/ Pavilion Floors shower repair product fully completed in 2-2 on 01/03/2025</i>
52. 2nd Floor	Unit 2-2	Shower # 22C (near slop sink room # 22D)	105 CMR 451.123	Maintenance: Shower curtain missing <i>Shower Curtain was replaced on 11/09/2024</i>
53. 2nd Floor	Unit 2-2	Shower # 22C (near slop sink room # 22D)	105 CMR 451.123	Maintenance: Walls dirty <i>Cleaned 11/9/2024. Sole Source/ Pavilion Floors shower repair product fully completed in 2-2 on 01/03/2025</i>
54. 2nd Floor	Unit 2-2	Shower # 22E (near cell # 15)	105 CMR 451.123	Maintenance: Objectionable odor observed <i>Cleaned 11/9/2024. Sole Source/ Pavilion Floors shower repair product fully completed in 2-2 on 01/03/2025</i>
55. 2nd Floor	Unit 2-2	Shower # 22E (near cell # 15)	105 CMR 451.123*	Maintenance: Shower curtain missing <i>Shower Curtain replaced on 11/09/2024</i>
56. 2nd Floor	Unit 2-2	Shower # 22H (near cell # 34)	105 CMR 451.123	Maintenance: Wall paint damaged <i>Sole Source/ Pavilion Floors shower repair product fully completed in 2-2 on 01/03/2025</i>
57. 2nd Floor	Unit 2-2	Shower # 22I (near cell # 32)	105 CMR 451.123	Maintenance: Walls dirty <i>Cleaned 11/9/2024. Sole Source/ Pavilion Floors shower repair product fully completed in 2-2 on 01/03/2025</i>
58. 2nd Floor	Unit 2-2	Cells	105 CMR 451.103	Mattresses: Mattress cover missing in cell # 1, 5, 13, 15, and 17 <i>All mattresses were replaced by Dep. Pena on 11/11/2024</i>
59. Contact Visits/Roll Call	Classification		105 CMR 451.200	Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, refrigerator gaskets moldy and damaged <i>Cleaned on 11/11/2025</i>
60. Entry Level	Communications Office # 1080		105 CMR 451.200	Food Storage, Preparation and Service: Food storage not in

			compliance with 105 CMR 590.000, excessive ice build-up observed in freezer <i>Excessive Ice Build-up in freezer was thawed on 11/18/2024</i>
61. Entry Level	Blue Shirt's Locker Room # 1075	105 CMR 451.110(A) *	Hygiene Supplies at Toilet and Handwash Sink: Electric hand dryer out-of-order <i>Department Electrician, Robert Jackson, notified. Excepted replacement before 1/31/2025</i>
62. Entry Level	Blue Shirt's Locker Room # 1075	105 CMR 451.123*	Maintenance: Ceiling tiles water damaged <i>Replaced 12/03/2024</i>
63. Ground Level	Staff Bathroom # G5	105 CMR 451.123	Maintenance: Ceiling vent dusty <i>Cleaned by civilian ground floor crew on 11/11/2024</i>
64. Ground Level	Staff Bathroom # G5	105 CMR 451.123	Maintenance: Wall paint damaged <i>Schedule to be repainted by Sgt. Bernard (Maintenance) before 01/31/2025</i>
65. Ground Level	Staff Bathroom # G5	105 CMR 451.123	Maintenance: Ceiling water damaged <i>Schedule to be repaired by Sgt. Bernard (Maintenance) before 01/31/2025</i>
66. Ground Level	Back Gate Control # G80	105 CMR 451.200	Food Storage, Preparation and Service: Food storage not in compliance with 105 CMR 590.000, excessive ice build-up in freezer <i>Excessive Ice Build-up in freezer was thawed on 11/18/2024</i>
67. Ground Level	West Mechanical # G18	105 CMR 451.130*	Plumbing: Plumbing not maintained in good repair, hot water supply leaking <i>Repaired with new rubber gasket on 12/15/2024 by Maintenance Dept.</i>
68. Food Service	Oven and Steamer Hood Area	105 CMR 451.200	Maintenance and Operation; Premises, Structure, Attachments, and Fixtures - Methods: Facility not cleaned as often as necessary, rodent droppings observed behind ovens. Standard found in 105 CMR 590; FC 6-501.12(A). <i>Cleaned On-Site 11/08/2024</i>
69. Food Service	Storage Cage	105 CMR 451.200	Maintenance and Operation; Premises, Structure, Attachments, and Fixtures - Methods: Facility not cleaned as often as necessary, rodent droppings observed. Standard found in 105 CMR 590; FC 6-501.12(A). <i>Cleaned On-Site 11/08/2024</i>
70. Food	Vegetable Walk-in # 3	105 CMR 451.200	Limitation of Growth of Corrected

Service			Organisms of Public Health Concern, Temperature and Time Control: Refrigerated time/temperature control for safety food prepared on site not clearly marked indicating the date or day by which the food shall be consumed or discarded (Pf). Standard found in 105 CMR 590; FC 3-501.17(A)	on-site
71. Food Service	Vegetable Walk-in # 3	105 CMR 451.200	Characteristics; Condition: Food not safe, unadulterated, and honestly presented (Pf), moldy produce observed. Standard found in 105 CMR 590; FC 3-101.11.	Corrected on-site
72. Food Service	Milk Walk-in # 4	105 CMR 451.200	Preventing Contamination after Receiving; Preventing Food and Ingredient Contamination: Food not appropriately covered. Standard found in 105 CMR 590; FC 3-302.11(A)(4).	Corrected on-site
73. Food Service	Mop Cage	105 CMR 451.200	Maintenance and Operation; Premises, Structure, Attachments, and Fixtures - Methods: Facility not cleaned as often as necessary, rodent droppings observed. Standard found in 105 CMR 590; FC 6-501.12(A). <i>Cleaned On-Site 11/08/2024</i>	

Deficiencies under the Recommended Standards (.300 series)

20 new deficiencies and 17 repeat deficiencies (indicated by an *) were found during the inspection:

1.	6th Floor	Unit 6-1A	Storage Room # 61G	105 CMR 451.360	Protective Measures: Rodent droppings observed <i>Cleaned on 11/08/2024</i>
2.	6th Floor	Unit 6-1A	Kitchenette	105 CMR 451.360*	Protective Measures: Rodent droppings observed <i>Cleaned on 11/08/2024</i>
3.	6th Floor	Unit 6-1A	Slop Sink Room # 61B	105 CMR 451.360*	Protective Measures: Rodent droppings observed <i>Cleaned on 11/08/2024</i>
4.	6th Floor	Unit 6-1	Slop Sink Room	105 CMR 451.353	Interior Maintenance: Wet mop

					stored upside down <i>Mop placed right side up on 11/08/2024</i>
5.	6th Floor	Unit 6-1	Second Floor Storage Room	105 CMR 451.360*	Protective Measures: Rodent droppings observed <i>Cleaned on 11/08/2024</i>
6.	6th Floor	Unit 6-3 (Safekeep for BPD)	Kitchenette	105 CMR 451.353*	Interior Maintenance: Hand wash sink dirty <i>Cleaned on 11/09/2024</i>
7.	6th Floor	Unit 6-3 (Safekeep for BPD)	Kitchenette	105 CMR 451.360*	Protective Measures: Rodent droppings observed <i>Cleaned on 11/09/2024</i>
8.	6th Floor	Unit 6-4	Cells	105 CMR 451.353	Interior Maintenance: Ceiling dirty in cell # 17 <i>Cell Ceiling cleaned by unit workers 11/18/2024</i>
9.	6th Floor	Unit 6-4	Cells	105 CMR 451.353	Interior Maintenance: Wall vent blocked in cell # 8, 11, and 27 <i>Blockages removed 11/13/2024</i>
10.	5th Floor	Psychiatric Housing Unit # 5552	Storage # 5555	105 CMR 451.383(B)	Fire Safety System: Facility not in compliance with 780 CMR Massachusetts Building Code provisions for fire safety <i>Medical Supplies moved under the 18 inch ceiling variance on 11/13/2024. Medical Dept., Christina Benner, notified to maintain this measurement.</i>
11.	5th Floor	Medical Area	Male Staff Bathroom # 5093	105 CMR 451.353*	Interior Maintenance: Floor damaged outside bathroom <i>Expected date of repair by the Maintenance Dept. Sgt. Bernard is before 02/28/2025</i>
12.	4th Floor	Unit 4-1	Kitchenette	105 CMR 451.360	Protective Measures: Rodent droppings observed <i>Cleaned 11/08/2024</i>
13.	4th Floor	Unit 4-1	Kitchenette	105 CMR 451.353	Interior Maintenance: Handwash sink dirty <i>Cleaned 11/08/2024</i>
14.	4th Floor	Unit 4-1	Slop Sink Room # 41N	105 CMR 451.353	Interior Maintenance: Wet mop stored in bucket <i>Mop removed and placed right side up on 11/08/2024</i>
15.	4th Floor	Unit 4-1	Storage Closet	105 CMR 451.360	Protective Measures: Rodent droppings observed <i>Cleaned 11/08/2024</i>
16.	4th Floor	Unit 4-1	Storage Closet	105 CMR 451.353	Interior Maintenance: Wet mop stored in bucket <i>Mop removed and placed right side up on 11/08/2024</i>
17.	4th Floor	Unit 4-2	Kitchenette	105 CMR 451.360	Protective Measures: Rodent droppings observed

<i>Cleaned on 11/09/2024</i>				
18. 4th Floor	Unit 4-4	Common Area	105 CMR 451.353	Interior Maintenance: Mold observed on ceiling near closet # 44G <i>Ceiling damage scheduled for repair before 03/31/2025</i>
19. 4th Floor	Unit 4-4	Common Area	105 CMR 451.353	Interior Maintenance: Wall mounted telephone # 1 out-of-order <i>Telephone #1 repaired by contractor Securus on 12/03/2024</i>
20. 4th Floor	Unit 4-4	Common Area	105 CMR 451.353*	Interior Maintenance: Ceiling damaged near closet # 44G <i>Ceiling damage scheduled for repair before 03/31/2025</i>
21. 4th Floor	Unit 4-4	Kitchenette	105 CMR 451.360*	Protective Measures: Rodent droppings observed <i>Cleaned on 11/09/2024</i>
22. 4th Floor	Unit 4-4	Closet # 44G	105 CMR 451.360*	Protective Measures: Rodent droppings observed <i>Cleaned on 11/09/2024</i>
23. 4th Floor	Unit 4-4	Slop Sink Room # 44C	105 CMR 451.353	Interior Maintenance: Wet mop stored upside down <i>Mop turned right side up on 11/08/2024</i>
24. 4th Floor	Unit 4-4	Slop Sink Room # 44C	105 CMR 451.353	Interior Maintenance: Chemical bottle leaking <i>Chemical Bottle removed 11/08/2024</i>
25. 4th Floor	Unit 4-4	Cells	105 CMR 451.353	Interior Maintenance: Wall vent blocked in cell # 8 <i>Blockage removed 11/12/2024</i>
26. 2nd Floor	Control 2-1 & 2-2	Main Area	105 CMR 451.353	Desk surface damaged <i>Bill Shea Countertops on site for replacement quote 01/20/2025</i>
27. Entry Level	Weight Room # 1070		105 CMR 451.353*	Interior Maintenance: Floor tiles damaged <i>State contract bids currently out for gym repair. Received 1 of 3 quotes submitted by Rogue Fitness as of 01/02/2025</i>
28. Ground Level	Store Room # G11		105 CMR 451.353	Interior Maintenance: Wet mop stored in bucket <i>Mope removed 11/11/2024</i>
29. Ground Level	Loading Dock # G26		105 CMR 451.350*	Structural Maintenance: Garage door not rodent and weather tight <i>Maintenance notified. Scheduled for repair before 03/03/2025</i>
30. Ground Level	Laundry Room # G23/G29		105 CMR 451. 353*	Interior Maintenance: Ceiling water damaged in storage closet <i>Scheduled for repair by 02/28/2025</i>
31. Ground Level	Loading Dock # G26		105 CMR 451.360*	Protective Measures: Rodent droppings observed <i>Cleaned 11/12/2024</i>
32. Ground	Garbage Room # G37		105 CMR 451.350*	Structural Maintenance: Garage door

Level				not rodent and weather tight <i>Maintenance notified. Scheduled for repair before 03/03/2025</i>
33. Ground Level	Garbage Room # G37		105 CMR 451.360*	Protective Measures: Rodent droppings observed on floor <i>Cleaned 11/12/2024</i>
34. Ground Level	Boston Police Booking Area		105 CMR 451.353*	Interior Maintenance: Ceiling tiles missing, and water damaged <i>Maintenance notified excepted date of report 2/1/2025</i>
35. Ground Level	Male Booking Area	Control	105 CMR 451.353*	Interior Maintenance: Floor damaged <i>Maintenance notified excepted date of report 2/1/2025</i>

SECTION 2: Areas Found to be in Compliance

EHRIS inspected 102 additional areas of the facility which were found to be in compliance.

Section 3: Areas EHRIS did not inspect

EHRIS did not inspect 13 areas of the facility because they were either in use, locked, or under construction.

1. Floor 6.5	Storage Room # 6504		Unable to Inspect - Locked
2. Floor 6.5	Inmate Bathroom # 6505		Unable to Inspect - Not in Use
3. Floor 6.5	Inmate Bathroom # 6506		Unable to Inspect - Not in Use
4. 6th Floor	Unit 6-4	Storage Room # 64F	Unable to Inspect - Locked
5. 5th Floor	Medical Area	Room # 5029	Unable to Inspect - In Use
6. 5th Floor	Psychiatric Housing Unit # 5552	Shower # 55A	Unable to Inspect - In Use
7. 4th Floor	Unit 4-1	Shower # 41G (near cell # 10)	Unable to Inspect - In Use
8. 4th Floor	Unit 4-2	Storage Room # 42F	Unable to Inspect - Locked
9. 4th Floor	Unit 4-2	Shower # 42G	Unable to Inspect - In Use
10. Floor 3.5	Education	Bathroom # 3520	Unable to Inspect - In Use
11. 2nd Floor	Unit 2-1		Unable to Inspect - Under Construction
12. 2nd Floor	Unit 2-3		Unable to Inspect - Under Construction
13. 2nd Floor	Unit 2-4		Unable to Inspect - Under Construction

SECTION 5: Plan of Correction

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please submit a plan of correction within 10 working days of receipt of this notice. The Plan of Correction must include:

1. Specific corrective steps to be taken
2. A timetable for the corrective actions for larger projects
3. The date by which correction will be achieved
4. Any interim measures being implemented to ensure the health and safety of incarcerated individuals and facility staff

5. The plan should be signed by the Superintendent or Administrator and submitted to my attention, at the address listed above.

SECTION 4: Observations and Recommendations

1. The inmate population was 318 at the time of the inspection.
2. At the time of inspection, the EHRS recommended re-numbering all showers throughout the institution. This will assist the EHRS and Sheriff's Department employees to better recognize where issues exist.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Correctional Facilities" [105 CMR 451.000](#) is available in both PDF and RTF formats. For more specific information about the food standards, you can download the merged food code, which can be found [here](#).

An inspection may also include observations of other conditions which could constitute a threat to the health or safety of inmates or employees, including but not limited to the standards set forth by the Department as follows, and report on such pursuant to 451.402(B). You can use these links below to review these standards:

- [105 CMR 205.000](#): Minimum Standards Governing Medical Records and Conduct of Physical Examinations in Correctional Facilities
- [105 CMR 480.000](#): Minimum requirements for the Management of Medical or Biological Waste
- [105 CMR 500.000](#): Good Manufacturing Practices for Food

This inspection report is true and accurate to the best of my knowledge.

Sincerely,

Hannah LeBeau
Environmental Health Inspector, EHRS, BCEH



MAURA T. HEALEY
Governor

KIMBERLEY DRISCOLL
Lieutenant Governor

The Commonwealth of Massachusetts

Executive Office of Health and Human Services

Department of Public Health

Bureau of Climate and Environmental Health

Division of Environmental Health Regulations and Standards

67 Forest Street, Suite # 100

Marlborough, MA 01752

Phone: 617-624-5757

KATHLEEN E. WALSH
Secretary

ROBERT GOLDSTEIN, MD, PhD
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

January 31, 2025

Steven W. Tompkins, Sheriff
Suffolk County Sheriff's Department
20 Bradston Street
Boston, MA 02118 (electronic copy)

Re: Plan of Correction – Suffolk County Jail, Boston

Dear Sheriff Tompkins:

The Massachusetts Department of Public Health, Division of Environmental Regulations and Standards (EHRS) has received your Plan of Correction in response to my inspection conducted on November 8, 2025. After review, the EHRS finds the plan addresses all the deficiencies noted with the following exceptions:

1. In instances where you indicate your department is receiving a quote for repair or “state contracts are out for bid” please provide a plan describing the interim measures you have implemented to ensure the health and safety of inmates and staff. In addition, we ask to be kept apprised of the funding progress.

Thank you for your prompt attention to this matter, should you have any questions please contact me at the address listed above.

Sincerely,

Hannah LeBeau
Environmental Health Inspector, EHRS, BCEH

cc: Jose Mojica, Superintendent
Sergeant Tyler Crocker, EHSO/FSO

(electronic copy)
(electronic copy)



STEVEN W. TOMPKINS
SHERIFF

Suffolk County Sheriff's Department

Jail
200 Nashua Street
Boston, MA 02114
(617) 635-1100

House of Correction
20 Bradston Street
Boston, MA 02118
(617) 635-1000



February 12, 2025

Hannah LeBeau, Environmental Health Inspector
Commonwealth of Massachusetts
Department of Public Health
5 Randolph Street
Canton, MA 02021

Dear Inspector LeBeau:

I wanted to follow up on the noted deficiency (see attachment) regarding our EHRS inspection at the Nashua Street Jail.

- The entry level weight room floor tiles: The union, JOEASC, is in the process of contracting out a company to replace all flooring and workout equipment. We have posted "caution" signs (see attachment) in the gym until the redesign of the gym is completed.
- 2nd Floor Control 2-1 & 2-2 desk surface: the Department is currently seeking quotes for replacing the control booth countertops. The goal is to have them all replaced in six months.

Please feel free to contact me if you have any questions,

Jose Mojica
Superintendent
Suffolk County Sheriff's Department
Boston, MA 02114
617-704-6663



MAURA T. HEALEY
Governor

KIMBERLEY DRISCOLL
Lieutenant Governor

The Commonwealth of Massachusetts

Executive Office of Health and Human Services

Department of Public Health

Bureau of Climate and Environmental Health

Division of Environmental Health Regulations and Standards

67 Forest Street, Suite # 100

Marlborough, MA 01752

Phone: 617-624-5757

KATHLEEN E. WALSH
Secretary

ROBERT GOLDSTEIN, MD, PhD
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

March 14, 2025

Steven W. Tompkins, Sheriff
Suffolk County Sheriff's Department
20 Bradston Street
Boston, MA 02118 (electronic copy)

Re: Plan of Correction – Suffolk County Jail, Boston

Dear Sheriff Tompkins:

The Massachusetts Department of Public Health, Division of Environmental Regulations and Standards (EHRS) has received your Plan of Correction dated March 11, 2025. After review, the EHRS finds the plan addresses all the deficiencies noted.

Thank you for your prompt attention to this matter, should you have any questions please contact me at the address listed above.

Sincerely,

Hannah LeBeau
Environmental Health Inspector, EHRS, BCEH

cc: Jose Mojica, Superintendent
Sergeant Tyler Crocker, EHSO/FSO

(electronic copy)
(electronic copy)