



The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Environmental Health
Community Sanitation Program
5 Randolph Street, Canton, MA 02021
Phone: 781-828-7700 Fax: 781-828-7703

CHARLES D. BAKER
Governor

KARYN E. POLITO
Lieutenant Governor

MARYLOU SUDDERS
Secretary

MARGRET R. COOKE
Commissioner

Tel: 617-624-6000
www.mass.gov/dph

December 2, 2022

Jeffrey Gonsalves, Superintendent
MASAC in Plymouth
Myles Standish State Forest
Plymouth, MA 02360 (electronic copy)

Re: Plan of Correction – MASAC in Plymouth

Dear Superintendent Gonsalves:

The Massachusetts Department of Public Health, Community Sanitation Program (CSP) has received your Plan of Correction in response to my inspection on October 28, 2022. After review, the CSP finds the plan does not appropriately address all of the violation noted in the report:

1. Where you indicate “The DCAMM project / Gensler study projects the start of renovations in the spring/summer of 2023,” the CSP cannot approve any items that do not identify a reasonable time frame for repair. Please provide an approximate date for the completion of these repairs. The CSP remains concerned with the uncorrected violations and asks you to provide a plan describing the interim measures you have implemented to ensure the health and safety of inmates and staff. In addition we ask to be kept apprised of the DCAMM funding progress.
2. Where you indicate “unimpeded access to toilet and handwash facilities are available within close proximity to this area,” for the Medical Treatment Room near Central Control, and the Medical Offices in the HSU inside C Dorm, the CSP remains concerned with the lack of a handwash sink available to medical staff. In addition to 105 CMR 451.109 and 451.112, the CSP also refers to 105 CMR 205.103 where it states that the required examination room “shall contain a handwash sink with hot and cold running water.” The CSP does not feel the provided handwash sink and toilet facilities are convenient for medical staff as they are shared by all other employees and may not be readily available as needed. The CSP recommends installing convenient handwash sinks in all areas where medical treatment is provided for the medical staff to utilize at all times.
3. In regards to the issue of overcrowding, the Department appreciates the limitations of correctional facilities and the need to accommodate the ever-increasing population; however we remain concerned with the overcrowded conditions.
4. Please provide a corrective action and estimated date of repair for the damaged floor surface at the entrance to the A Dorm bathroom area.

Thank you for your prompt attention to this matter, should you have any questions please contact me at the address listed above.

Sincerely,



Patrick Wallace
Environmental Health Inspector, CSP, BEH

cc: Margret R. Cooke, Commissioner, DPH
 Nalina Narain, Director, BEH
 Steven Hughes, Director, CSP, BEH
 Marylou Sudders, Secretary, Executive Office of Health and Human Services (electronic copy)
 Carol A. Mici, Commissioner, DOC (electronic copy)
 Thomas Turco, Secretary, EOPSS (electronic copy)
 Timothy Gotovich, Director, Policy Development and Compliance Unit (electronic copy)
 Michelle Offley, EHSO (electronic copy)
 Karen Keane, Health Director, Plymouth Health Department (electronic copy)
 Clerk, Massachusetts House of Representatives (electronic copy)
 Clerk, Massachusetts Senate (electronic copy)