



The Commonwealth of Massachusetts
Executive Office of Health and Human Services
Department of Public Health
Bureau of Environmental Health
Community Sanitation Program
5 Randolph Street, Canton, MA 02021
Phone: 781-828-7700 Fax: 781-774-6700

CHARLES D. BAKER
Governor

KARYN E. POLITO
Lieutenant Governor

MARYLOU SUDDERS
Secretary

MONICA BHAREL, MD, MPH
Commissioner

Tel: 617-624-6000
www.mass.gov/dnh

May 8, 2020

David Duarte, Superintendent
Massachusetts Treatment Center
30 Administration Road
Bridgewater, MA 02324 (electronic copy)

Re: Plan or Correction – Massachusetts Treatment Center, Bridgewater

Dear Superintendent Duarte:

The Massachusetts Department of Public Health, Community Sanitation Program (CSP) has received your Plan of Correction in response to my inspection on February 26 and 27, 2020. After review, the CSP finds the plan appropriately addresses all of the violations noted in the report with the following exceptions:

1. Please provide a corrective action and date of completion for violations where you indicate the following:
 - a. Titan roofing contacted to assess and repair;
 - b. Suburban glass on site 3/12/20, quote pending repair/replacement;
 - c. Window assessed not a security risk to be submitted for capital funding;
 - d. Assessed not a security concern; and
 - e. Capital Project – Window Replacement.
2. Please provide a corrective action and date of completion for the following Food Service violations:
 - a. Stainless trays stacked wet;
 - b. Gaskets damaged on Cooler # 6;
 - c. Pipes leaking next to kettles;
 - d. Missing backflow prevention device on 3-Compartment sink;
 - e. Exterior door not tight fitting at bottom in Recycling Area;
3. Please provide a corrective action and date of completion for the following violations:
 - a. Padding damaged on exercise equipment in the Gym;
 - b. Windows broken in the Back Office of the Gym; and
 - c. Gaskets damaged on refrigerator in Staff Break Room of South 1 Modular Unit.

Thank you for your prompt attention to this matter, should you have any questions please contact me at the address listed above.

Sincerely,



Patrick Wallace
Environmental Health Inspector, CSP, BEH

cc: Monica Bharel, MD, MPH, Commissioner, DPH
Jana Ferguson, Director, BEH
Steven Hughes, Director, CSP, BEH
Marylou Sudders, Secretary, Executive Office of Health and Human Services (electronic copy)
Carol A. Mici, Commissioner, DOC (electronic copy)
Thomas Turco, Secretary, EOPSS (electronic copy)
Timothy Gotovich, Director, Policy Development and Compliance Unit (electronic copy)
Victor Correia, Deputy Superintendent (electronic copy)
Kam Goldstone, EHSO/FSO (electronic copy)
Eric J. Badger, CHO, Health Agent, Bridgewater Health Department (electronic copy)
Clerk, Massachusetts House of Representatives (electronic copy)
Clerk, Massachusetts Senate (electronic copy)